

 **ANALYTICAL REPORT****PREPARED FOR**

Attn: Dr. Lillian Ramos
Passaic Family Head Start, Inc.
68 Third Street
Passaic, New Jersey 07055

Generated 7/23/2024 3:12:48 PM

JOB DESCRIPTION

Passaic Family Head Start, Inc.

JOB NUMBER

630-90109-1

Eurofins Environment Testing Philadelphia, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Philadelphia, LLC Project Manager.

Authorization



Generated
7/23/2024 3:12:48 PM

Authorized for release by
Tasha Smith, Project Manager
tasha.smith@et.eurofinsus.com
(215)355-3900

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by Eurofins Philadelphia field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification # 02015.

VL = field staff performs tests under NJ State certification # 06005.

WG = field staff performs tests under NJ State certification # PA001, PA State certification # 48-01334.

H = field staff performs tests under NJ NELAP certification # PA093, PA NELAP certification # 46-05499.

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. Eurofins Philadelphia is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· Eurofins Philadelphia is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by Eurofins Philadelphia : Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).



Case Narrative

Client: Passaic Family Head Start, Inc.
Project: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Job ID: 630-90109-1

Eurofins Environment Testing Philadelphia,

Job Narrative 630-90109-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 7/8/2024 10:09 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 28.9°C.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Sample Summary

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-90109-1	CLASSROOM 1A	Drinking Water	07/07/24 09:44	07/08/24 10:09
630-90109-2	CLASSROOM 1B	Drinking Water	07/07/24 09:46	07/08/24 10:09
630-90109-3	CLASSROOM 1C	Drinking Water	07/07/24 09:50	07/08/24 10:09
630-90109-4	CLASSROOM 1D	Drinking Water	07/07/24 09:51	07/08/24 10:09
630-90109-5	CLASSROOM 1E	Drinking Water	07/07/24 09:53	07/08/24 10:09
630-90109-6	CLASSROOM 2A	Drinking Water	07/07/24 10:11	07/08/24 10:09
630-90109-7	KITCHEN SMALL SINK	Drinking Water	07/07/24 09:58	07/08/24 10:09
630-90109-8	KITCHEN 3 COMPARTMENT SINK	Drinking Water	07/07/24 09:59	07/08/24 10:09
630-90109-9	1ST FLOOR WATER COOLER	Drinking Water	07/07/24 10:03	07/08/24 10:09
630-90109-10	1ST FLOOR STAFF BATHROOM	Drinking Water	07/07/24 10:01	07/08/24 10:09
630-90109-11	2ND FLOOR WATER COOLER	Drinking Water	07/07/24 10:09	07/08/24 10:09
630-90109-12	2ND FLOOR STAFF BATHROOM	Drinking Water	07/07/24 10:12	07/08/24 10:09

Client Sample Results

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Client Sample ID: CLASSROOM 1A

Lab Sample ID: 630-90109-1

Date Collected: 07/07/24 09:44

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	23		10	ug/L		07/23/24 10:46	1	F7JF
Lead	ND		1.0	ug/L		07/23/24 10:46	1	F7JF

Client Sample ID: CLASSROOM 1B

Lab Sample ID: 630-90109-2

Date Collected: 07/07/24 09:46

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	72		10	ug/L		07/16/24 10:20	1	F7JF
Lead	ND		1.0	ug/L		07/16/24 10:20	1	F7JF

Client Sample ID: CLASSROOM 1C

Lab Sample ID: 630-90109-3

Date Collected: 07/07/24 09:50

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	24		10	ug/L		07/12/24 11:15	1	F7JF
Lead	1.4		1.0	ug/L		07/12/24 11:15	1	F7JF

Client Sample ID: CLASSROOM 1D

Lab Sample ID: 630-90109-4

Date Collected: 07/07/24 09:51

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	92		10	ug/L		07/17/24 11:31	1	F7JF
Lead	ND		1.0	ug/L		07/17/24 11:31	1	F7JF

Client Sample ID: CLASSROOM 1E

Lab Sample ID: 630-90109-5

Date Collected: 07/07/24 09:53

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	130		10	ug/L		07/23/24 10:40	1	F7JF
Lead	1.0		1.0	ug/L		07/23/24 10:40	1	F7JF

Client Sample ID: CLASSROOM 2A

Lab Sample ID: 630-90109-6

Date Collected: 07/07/24 10:11

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	67		10	ug/L		07/17/24 11:33	1	F7JF
Lead	1.1		1.0	ug/L		07/17/24 11:33	1	F7JF

Client Sample Results

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Client Sample ID: KITCHEN SMALL SINK

Lab Sample ID: 630-90109-7

Date Collected: 07/07/24 09:58

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	220		10	ug/L		07/16/24 13:57	1	F7JF
Lead	ND		1.0	ug/L		07/16/24 13:57	1	F7JF

Client Sample ID: KITCHEN 3 COMPARTMENT SINK

Lab Sample ID: 630-90109-8

Date Collected: 07/07/24 09:59

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	39		10	ug/L		07/16/24 13:58	1	F7JF
Lead	ND		1.0	ug/L		07/16/24 13:58	1	F7JF

Client Sample ID: 1ST FLOOR WATER COOLER

Lab Sample ID: 630-90109-9

Date Collected: 07/07/24 10:03

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	86		10	ug/L		07/12/24 11:16	1	F7JF
Lead	1.5		1.0	ug/L		07/12/24 11:16	1	F7JF

Client Sample ID: 1ST FLOOR STAFF BATHROOM

Lab Sample ID: 630-90109-10

Date Collected: 07/07/24 10:01

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	120		10	ug/L		07/16/24 14:00	1	F7JF
Lead	ND		1.0	ug/L		07/16/24 14:00	1	F7JF

Client Sample ID: 2ND FLOOR WATER COOLER

Lab Sample ID: 630-90109-11

Date Collected: 07/07/24 10:09

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	80		10	ug/L		07/16/24 14:06	1	F7JF
Lead	2.0		1.0	ug/L		07/16/24 14:06	1	F7JF

Client Sample ID: 2ND FLOOR STAFF BATHROOM

Lab Sample ID: 630-90109-12

Date Collected: 07/07/24 10:12

Matrix: Drinking Water

Date Received: 07/08/24 10:09

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	68		10	ug/L		07/16/24 14:07	1	F7JF
Lead	1.3		1.0	ug/L		07/16/24 14:07	1	F7JF

Action Limit Summary

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Client Sample ID: CLASSROOM 1A

Lab Sample ID: 630-90109-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	23		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: CLASSROOM 1B

Lab Sample ID: 630-90109-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	72		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: CLASSROOM 1C

Lab Sample ID: 630-90109-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	24		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	1.4		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: CLASSROOM 1D

Lab Sample ID: 630-90109-4

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	92		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: CLASSROOM 1E

Lab Sample ID: 630-90109-5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	130		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	1.0		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Client Sample ID: CLASSROOM 2A

Lab Sample ID: 630-90109-6

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	67		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	1.1		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: KITCHEN SMALL SINK

Lab Sample ID: 630-90109-7

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	220		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: KITCHEN 3 COMPARTMENT SINK

Lab Sample ID: 630-90109-8

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	39		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: 1ST FLOOR WATER COOLER

Lab Sample ID: 630-90109-9

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	86		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	1.5		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: 1ST FLOOR STAFF BATHROOM

Lab Sample ID: 630-90109-10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	120		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Client Sample ID: 2ND FLOOR WATER COOLER

Lab Sample ID: 630-90109-11

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	80		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	2.0		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: 2ND FLOOR STAFF BATHROOM

Lab Sample ID: 630-90109-12

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	PA MCL	RL	Method	Prep Type
				Limit			
Copper	68		ug/L	1300.0	10	200.8 Rev 5.4	Total/NA
Lead	1.3		ug/L	15.000	1.0	200.8 Rev 5.4	Total/NA

Accreditation/Certification and Definitions Summary

Client: Passaic Family Head Start, Inc.
 Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Pennsylvania	NELAP	36-00037	01-31-25

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Method Summary

Client: Passaic Family Head Start, Inc.
Project/Site: Passaic Family Head Start, Inc.

Job ID: 630-90109-1


Method	Method Description	Protocol	Laboratory
200.8 Rev 5.4	Metals (ICP/MS)	EPA	ELLE
200.8	Preparation, Total Metals	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Eurofins Environment Testing Philadelphia,

795 Horsham Road
 Horsham, PA 19044-0962
 Phone: 215-355-3900

Chain of Custody Record



eurofins | Environment Testing

Client Information (Sub Contract Lab)		Sampler:		Lab PM Smith, Tasha N		Carrier Tracking No(s):		COC No: 630-14686 1			
Client Contact: Shipping/Receiving		Phone:		E-Mail: tasha.smith@et.eurofins.com		State of Origin: Pennsylvania		Page: Page 1 of 2			
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - Pennsylvania				Job #: 630-90109-1			
Address: 2425 New Holland Pike,		Due Date Requested: 7/22/2024		Analysis Requested						Preservation Codes:	
City: Lancaster		TAT Requested (days):									
State, Zip: PA, 17601		PO #:									
Phone: 717-656-2300(Tel)		WO #:									
Email:		Project #: 63007967									
Project Name: Passaic Family Head Start, Inc.		SSOW#:		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Total Number of Containers			
Site:		Project #:		200.B/MTL_ND_Prep (MOD) Copper and Lead		Other:		Special Instructions/Note:			
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=water/oil, BT=Tissue, A=Air)			
								Preservation Code:			
CLASSROOM 1A (630-90109-1)		7/7/24		09:44 Eastern		Drinking Water		X			
CLASSROOM 1B (630-90109-2)		7/7/24		09:46 Eastern		Drinking Water		X			
CLASSROOM 1C (630-90109-3)		7/7/24		09:50 Eastern		Drinking Water		X			
CLASSROOM 1D (630-90109-4)		7/7/24		09:51 Eastern		Drinking Water		X			
CLASSROOM 1E (630-90109-5)		7/7/24		09:53 Eastern		Drinking Water		X			
CLASSROOM 2A (630-90109-6)		7/7/24		10:11 Eastern		Drinking Water		X			
KITCHEN SMALL SINK (630-90109-7)		7/7/24		09:58 Eastern		Drinking Water		X			
KITCHEN 3 COMPARTMENT SINK (630-90109-8)		7/7/24		09:59 Eastern		Drinking Water		X			
1ST FLOOR WATER COOLER (630-90109-9)		7/7/24		10:03 Eastern		Drinking Water		X			
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.</p>											
Possible Hazard Identification					Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)						
Unconfirmed					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months						
Deliverable Requested: I, II, III, IV, Other (specify)					Primary Deliverable Rank: 1						
Special Instructions/QC Requirements:											
Empty Kit Relinquished by:			Date:		Time:		Method of Shipment:				
Relinquished by: <i>[Signature]</i>			Date/Time: 7/8/24 1520		Company: <i>[Signature]</i>		Received by: <i>[Signature]</i>				
Relinquished by:			Date/Time:		Company:		Received by:				
Relinquished by:			Date/Time:		Company:		Received by: <i>[Signature]</i>				
Custody Seals Intact:		Custody Seal No.:			Cooler Temperature(s) °C and Other Remarks:						
▲ Yes ▲ No					4.20C R:3.8 C:3.4						

W

1
2
3
4
5
6
7
8

